


NOTES:

1. CONTRACTOR TO CONTACT C.O.B. ELECTRIC INSPECTOR TO DETERMINE THE APPROVED QUADRANT FOR CONDUIT RISER INSTALLATION.
2. C.O.B. ELECTRIC UTILITY TO PROVIDE CONDUIT RISER BRACKETS (AT COST TO CONTRACTOR).
3. CONTRACTOR TO PROVIDE & INSTALL (1) 10' SCH80 CONDUIT AT EACH POLE RISER SCH80 SWEEP.
4. CONTRACTOR TO PROVIDE ADEQUATE AMOUNT OF SCH40 10' CONDUIT SEGMENTS FOR C.O.B. ELECTRIC UTILITY TO EXTEND POLE RISER(S) TO THE APPROPRIATE OVERHEAD ELECTRIC LEVELS.
5. WOOD SPACERS MAY BE USED DURING BACKFILL PROCESS TO ENSURE CONDUITS ARE 5" AWAY AND DIRECTLY ALIGNED WITH POLE. C.O.B. ELECTRIC INSPECTOR CAN PROVIDE A TEMPORARY STANDOFF BRACKET NEAR THE POLE BASE TO ASSIST CONTRACTOR WITH CORRECT INSTALLATION.

REF: W-1010-15HDGAF



REVISED: 10/06/2011

APPROVED: *[Signature]* 10-31-11

STANDARD DRAWINGS

CONDUIT STANDOFF BRACKETS
FOR POLE RISER INSTALLATIONS

SD

600-03