


NOTES:

1. SEE C.O.B. STANDARD DRAWING #600-41 FOR ADDITIONAL 17"x30" CONCRETE HANDHOLE SPECIFICATIONS.
2. LOCATE HANDHOLE AS DIRECTED BY C.O.B. ELECTRIC UTILITY.
3. IDENTIFY POSSIBLE OBSTRUCTIONS. CONTACT C.O.B. ELECTRIC INSPECTOR IF OBSTRUCTIONS REQUIRE RELOCATION.
4. THE TOP OF THE HANDHOLE SHALL BE INSTALLED FLUSH WITH FINAL GRADE.
5. INSTALL A MINIMUM 8" OF 3/4" CRUSHED ROCK UNDER PULL BOX.

REF: 3312.2



REVISED: 03/08/2011

APPROVED: *RE: 10-31-11*

STANDARD DRAWINGS

DOUBLE CONCRETE HANDHOLE, 17"x30"

SD

600-42