


NOTES:

1. LOCATE VAULT AS DIRECTED BY C.O.B. ELECTRIC UTILITY.
2. INSTALL GROUNDING PER C.O.B. STANDARD DRAWING #600-21.
3. INSTALL A MINIMUM 8" OF 3/4" CRUSHED ROCK UNDER VAULT.
4. ALLOW UP TO 3" OF EXTRA EXCAVATION DEPTH FOR ADJUSTING LID TO FINAL GRADE.

REF: 3315.2



REVISED: 03/21/2011

APPROVED: *RE: 10-31-11*

STANDARD DRAWINGS

CONCRETE VAULT BASE, 48"x78"

SD

600-54